



"Serving People and the Environment"

Your Water Utility

Liberty Lake Sewer and Water District #1
22510 E Mission Ave
Liberty Lake, WA 99019

Bijay Adams—General Manager
509.922.5443
www.libertylake.org

Board of Commissioner's Meetings are held the second Monday of every month at 4:00 pm.

=====
East Side Liberty Lake Improvement Club (ESLLIC)
Denise Coyle—Manager
509.255.6837

=====
Greenridge Homeowner's Association
Deborah Deyche—President
509.255.6638

We at Liberty Lake Sewer & Water District #1 work around the clock to provide top quality water to every tap.

We ask all our customers to help us protect our sole source of water, the Spokane Valley-Rathdrum Prairie Aquifer, which is at the heart of our community, our way of life and our children's future.

For more aquifer info: www.spokaneaquifer.org

An Electronic version of this and past years Consumer Confidence Report's can be found on our website at: www.libertylake.org/ccr/ccr2013.pdf

Although we have learned through our monitoring and testing that some constituents have been detected, the EPA has determined that your water IS SAFE at these levels.

Arsenic in your drinking water has been reported at less than 10 ppb. This means that your drinking water currently meets EPA's newly revised drinking water standard for arsenic. In the future, your Consumer Confidence Report will reflect improved laboratory methods that will more accurately detect the level of arsenic (if any) in your drinking water. EPA believes that consumers should be aware of the uncertain health risks presented by very low levels of arsenic. EPA's standard balances the current understanding of arsenic's health effects against the costs of removing arsenic from drinking water.

Liberty Lake Sewer and Water District #1

East Side Liberty Lake Improvement Club
Greenridge Homeowners Association

YOUR TAP WATER IS SAFE TO DRINK!

2013 Annual Drinking Water Quality Report

Mandatory Health-Related Standards are Established by the Washington State Department of Health

Parameter	Unit of Measure	MCL	MCLG	Highest Detected Level—Pump Stations					Likely Source of Contamination	
				LLSWD		ESLLIC		Greenridge Estates		
				Mission	Kenney	Schultz	Valleyway	Sprague		Valleyway
Microbiology										
Total Coliform Bacteria				No Constituents Detected						
Fecal Coliform and E. Coli				No Constituents Detected						
120 Tests were taken for LLSWD during reporting period										
12 Tests were taken for ESLLIC										
15 Tests were taken for Greenridge										
Inorganic Chemicals										
Nitrates									Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	
LLSWD Tested for in 2013	ppm	10	10	1.150	1.600	0.760	0.520	0.549	<0.500	<0.500
ESLLIC Tested for in 2013										
Greenridge Tested for in 2013										
Synthetic Organic Compounds										
LLSWD Tested for in 2013				No Constituents Detected						
ESLLIC Tested for in 2012				No Constituents Detected						
Greenridge Tested for in 2013				No Constituents Detected						
Volatile Organic Compounds										
LLSWD Tested for in 2012				No Constituents Detected						
ESLLIC Tested for in 2010				No Constituents Detected						
Greenridge Tested for in 2010				No Constituents Detected						
Radioactive Compounds										
Radium 226 & 228										
Gross Alpha										
LLSWD Tested for in 2012				No Constituents Detected						
ESLLIC Tested for in 2010				No Constituents Detected						
Greenridge Tested for in 2010				No Constituents Detected						
Lead & Copper										
20 Homes in LLSWD were tested in 2012 for Lead & Copper which is regulated at the customer's tap.				Action Levels Not Exceeded						
10 Homes in ESLLIC were tested in 2011				Action Levels Not Exceeded						
10 Homes in Greenridge were tested April & Oct. 2013				Action Levels Not Exceeded						
Abbreviations										
ND = Not Detected ppm = parts per million ppb = parts per billion AL = Action Level - concentrations of a constituent which, if exceeded, triggers treatment or other requirements										
LLSWD = Liberty Lake Sewer and Water District #1 ESLLIC = East Side Liberty Lake Improvement Club Greenridge = Green Ridge Estates										

<p>MCL's are set at very stringent levels. To understand the possible health effects described from the many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.</p>	<p>Water Use Efficiency Rule and Annual Performance Reporting (LLSWD): Beginning January 22, 2008, water system plans submitted for review and approval through the WA Department of Health must include water use efficiency planning requirements. The water use efficiency rule affects all municipal water suppliers. All municipal water suppliers need to set water use efficiency goals and record these goals in planning documents and performance reports. As part of the Water Use Efficiency Rule, municipal water suppliers must set water use efficiency goals through a public process and report annually on their performance to customers, WA Department of Health, and also make the information available to the public.</p>	<p>The District through a public process has set four goals: 1) Reduce Per Capita Consumption from 240 gal/person/day, to 235 g/p/d 2) Outdoor Irrigation Reduction Program 3) Develop a Water Re-Use Program 4) Public Education and Outreach Program</p> <p>LLSWD Performance Report (January-December 2012): *The District has tracked its total water produced and purchased -Total Produced Water: 978,163,064 gallons -Authorized Consumption: 889,226,784 gallons</p>	<p>*Evaluated and calculated any distribution system leakage -Distribution System Leakage: 9.1% *The District has worked toward developing a Water Re-Use Program *The District has implemented an Irrigation Sensor Incentive Program -Awarded: 37-Soil Sensors, 8-Rain Sensors (since 2009) *The District has provided Public Education and Outreach on water use efficiency. *Delivered educational materials on water use and efficiency -Direct and Bulk Mailings, Local Newspaper, Website *The District included the WUE annual performance report progress in the 2012 Consumer Confidence Report; mailed, June 2013.</p>
---	---	--	---

