

Liberty Lake Sewer and Water District

Amendment 1 to the 2015 Standard Construction Specifications.

The following changes are hereby made with this amendment to the Liberty Lake Sewer and Water District, 2015 Standard Construction Specifications:

Section 9-30.5 Hydrants

Add the following:

Hydrants shall be equipped with storz connections on the pumper port. Connections shall be straight pattern with 6" NPT X 5" storz.

Section 9-30.6(7) Meter Boxes

Change this section to read:

Meter boxes for ¾-inch or 1-inch meters shall be straight wall polymer concrete as shown on standard plan No. 7-15-B. and standard plan No. 7-15-C with 13"x24" inside dimensions, constructed in 12-inch deep sections, with removable polymer concrete cover and hinged reader lid as manufactured by Armorcast Products Company, Part Number A6001946PCX12 or approved equal. Traffic covers shall be provided when required.

Meter boxes for meters larger than 1-inch up to 2-inch shall be straight wall polymer concrete as shown on standard plan No. 7-15D with removable concrete cover and hinged reader lid as manufactured by Armorcast Products Company, part number A600164PCX 12 or approved equal.

Water service vaults are required for meters larger than 2-inches in accordance with Section 9-30.4.

Section 9-30.6(8)A Meters ≤ 1-Inch

Change this section to read:

Section 9-30.6(8)A Meters ≤ ¾-Inch

All meters ¾-inch or smaller will be supplied by the District. They will be remote read units, manufactured by sensus.

Section 9-30.6(8)B Meters larger than 1 Inch

Change this section to read:

Section 9-30.6(8)B Meters larger than ¾-Inch

All Meters larger than ¾-inch will be purchased from the District. The manufacture and model for these meters will be determined by the District at their sole discretion.

Section 9-30.6(8)C Meter Yokes and Meter Connector Assemblies

Change this second paragraph to read:

Meter yokes for meters ¾-inch or smaller will be supplied by the District.